

OPTIX RECESSED 1200 2L LUMI 4K ALU SSA03
2023942



Produkteigenschaften

• OPTIX RECESSED 1200 2L LUMI 4000K ALU SSA03 ist eine Deckeneinbauleuchte für den Büro- und Bildungsbereich mit aluminisierter, besonders blendarmer Kunststoffoptik und einem Leuchtenkörper in der Farbe RAL9016. SylSmart Connected-fähig. 4.000 K neutralweiße LED. Farbwerttoleranz der 3-stufigen MacAdam-Ellipse. Für 4.000 K - Farbwiedergabeindex Ra >98. Melanopischer Quotient MEER: 0,782. Farbtreueindex R#: 93. Gamut-Index R#: 98. Für 4.000 K Lichtstrom: 3.800 lm. Leistungsaufnahme: 37 W. Systemeffizienz: 103 lm/W. UGR<16 Leuchtdichte b...

CIBSE TM66

Result				
Category	Points Scored	Maximum possible points	Assessment	
Product design	76	134.0	2.3	
Manufacturing	23.4	46.5	2	
Materials	7	24.0	1.2	
Ecosystem	21	43.0	2	
Overall performance	127.4	247.5	1.88	
				How to analyse the score
				0.0 to 0.5 Very poor circular economy performance
				0.5 to 1.5 Some circular economy functionality
				1.5 to 2.5 Definite/substantial progress to circularity
				2.5 to 4.0 Excellent circularity

Technical Memorandum (TM) 66 describes a Circular Economy’s main aims, how it can be achieved and what it’s practice will mean to the different branches of our industry like specifiers, manufacturers, contractors, and Facilities Managers.

The Circular Economy Assement Method for Manufacturing (CEAM-Make)’s list of 66 searching questions, the majority of which askfor back-up evidence, is split into four sections :

- Product Design :
Manufacturing :
Materials :
Ecosystem :
- Covering topics such as design for long life and repair
Additive and subtractive techniques and localisation
Usage of recyclable materials rather than virgin
Repair or upgrade services to complement circular economy design

The outcome of the assement is a single figure rating by which product comparisons can be made. A TM66 score demonstrates a product’s performance in the context of a Circular Economy

CIBSE (2021) Circular Economy Assessment Method - Make TM66 Digital Tool beta version 22nd October 2021 (London : Chartered Institution of Building Services Engineers)