

Concord

COLOSSAL 400mm 940 OPAL DIR+HAL WHITE DALI EM 2071154



Produkteigenschaften

• Runde, architektonische Leuchte mit einem Durchmesser von 400 mm, für Anbau- oder Pendelmontage geeignet. Pulverbeschichtetes Aluminiumgehäuse (RAL9016) mit opalem Polycarbonatdiffusor. Direkte/indirekte (Halo) Lichtverteilung, 2280 lm Lichtstrom, 21,2 W Systemleistung, 108 lm/W Systemeffizienz. DALI dimmbar. 3 Stunden integrierte Notbeleuchtung. Farbwiedergabeindex Ra >90, 4.000 K neutralweiße LED, Chromatizitätstoleranz der 3-stufigen MacAdam-Ellipse. IP40, IK03. 450 mA Antriebsstrom. Elektrische Schutzklasse 1, 220-240 V. Angegeben...

CIBSE TM66

Result			
Category	Points Scored	Maximum possible points	Assessment
Product design	65	134.0	2.3
Manufacturing	21.5	46.5	1.9
Materials	5	24.0	0.8
Ecosystem	18	43.0	1.7
Overall performance	109.5	247.5	1.68

How to analyse the score	
0.0 to 0.5	Very poor circular economy performance
0.5 to 1.5	Some circular economy functionality
1.5 to 2.5	Definite/substantial progress to circularity
2.5 to 4.0	Excellent circularity

Technical Memorandum (TM) 66 describes a Circular Economy's main aims, how it can be achieved and what its practice will mean to the different branches of our industry like specifiers, manufacturers, contractors, and Facilities Managers.

The Circular Economy Assessment Method for Manufacturing (CEAM-Make)'s list of 66 searching questions, the majority of which ask for back-up evidence, is split into four sections :

- Product Design : Covering topics such as design for long life and repair
- Manufacturing : Additive and subtractive techniques and localisation
- Materials : Usage of recyclable materials rather than virgin
- Ecosystem : Repair or upgrade services to complement circular economy design

The outcome of the assessment is a single figure rating by which product comparisons can be made. A TM66 score demonstrates a product's performance in the context of a Circular Economy

CIBSE (2021) Circular Economy Assessment Method - Make TM66 Digital Tool beta version 22nd October 2021 (London : Chartered Institution of Building Services Engineers)