Concord

OPTIX RECESSED 1200X300 1L 4000K ALU DALI EM **2023658**



Características del producto

• OPTIX RECESSED 1200X300 1L 4000K ALU DALI EM is a high efficacy low glare luminaire for office and education applications. Ceiling recessed 1200x300 mm. Aluminised plastic extra low glare optics in 1 line configuration. White RAL9016 fixture body. Constant current driver. 3hr maintained emergency version. 4000K Neutral White LED, CRI>80, chromaticity tolerance of 3-step MacAdam ellipse. Luminous flux 3400lm. Power consumption 27W. Luminaire efficacy 126lm/W. Lifespan: 48,500 hours L90B10. UGR<16, Luminance at 65°<200 Cd/m2, IK07, IP20...

CIBSE TM66

Result			
	_	,	
Category	Points Scored	Maximum possible points	Assessment
Product design	76	134.0	2.3
Manufacturing	23.4	46.5	2
Materials	7	24.0	1.2
Ecosystem	21	43.0	2
Overall performance	127.4	247.5	1.88

How to analyse the score			
0.0 to 0.5	Very poor circular economy performance		
0.5 to 1.5	Some circular economy functionality		
1.5 to 2.5	Definite/substantial progress to circularity		
2.5 to 4.0	Excellent circularity		

Technical Memorandum (TM) 66 describes a Circular Economy's main aims, how it can be achieved and what it's practice will mean to the different branches of our industry like specifiers, manufacturers, contractors, and Facilities Managers.

The Circular Economy Assement Method for Manufacturing (CEAM-Make)'s list of 66 searching questions, the majority of which askfor back-up evidence, is split into four sections:

Product Design: Covering topics such as design for long life and repair

Manufacturing: Additive and subtractive techniques and localisation

Materials: Usage of recyclable materials rather than virgin

Ecosystem : Repair or upgrade services to complement circular economy design

The outcome of the assement is a single figure rating by which product comparisons can be made. A TM66 score demonstrates a product's performance in the context of a Circular Economy

CIBSE (2021) Circular Economy Assessment Method - Make TM66 Digital Tool beta version 22nd October 2021 (London: Chartered Institution of Building Services Engineers)

