Concord

COLOSSAL 400mm 840 PRISM DIR+HAL WHITE EM 2071147



Caractéristiques de la gamme

 400mm diameter circular architectural luminaire, can be surface mounted or suspended. Powder coated aluminium housing (RAL9016) with PMMA prismatic diffuser. Direct/indirect (halo) light distribution, 2015lm luminuous flux, 16W system power, 126lm/W luminiaire efficacy. Constant current driver. 3 hours integrated emergency. Colour rendering index Ra >80, 4000K Neutral White LED, chromaticity tolerance of 3-step MacAdam ellipse. IP40, IK03. 350mA drive current. UGR≤19. Electrical protection Class1, 220-240V. Reported lifetime 66k hours...

CIBSE TM66

Result	esult						
Category	Points Scored	Maximum possible points	Assessment		How to analyse the score		
Product design	65	134.0	2.3		0.0 to 0.5	Very poor circular economy performar	
Manufacturing	21.5	46.5	1.9		0.5 to 1.5	Some circular economy functionality	
Materials	5	24.0	0.8		1.5 to 2.5	Definite/substantial progress to circula	
Ecosystem	18	43.0	1.7		2.5 to 4.0	Excellent circularity	
Overall performance	109.5	247.5	1.68				

Technical Memorandum (TM) 66 describes a Circular Economy's main aims, how it can be achieved and what it's practice will mean to the different branches of our industry like specifiers, manufacturers, contractors, and Facilities Managers.

The Circular Economy Assement Method for Manufacturing (CEAM-Make)'s list of 66 searching questions, the majority of which askfor back-up evidence, is split into four sections :

Product Design :	Covering topics such as design for long life and repair
Manufacturing :	Additive and subtractive techniques and localisation
Materials :	Usage of recyclable materials rather than virgin
Ecosystem :	Repair or upgrade services to complement circular economy design

The outcome of the assement is a single figure rating by which product comparisons can be made. A TM66 score demonstrates a product's performance in the context of a Circular Economy

CIBSE (2021) Circular Economy Assessment Method - Make TM66 Digital Tool beta version 22nd October 2021 (London : Chartered Institution of Building Services Engineers)

