

Concord

Equinox 165 20W 2500lm 940 SSA01D Blanc

2059935



Caractéristiques de la gamme

• Equinox 165 20W 2500lm 940 SSA01D Blanc - Concord Equinox bouscule la façon d’appréhender le downlight en offrant une 3^{ème} dimension à sa fonction d’éclairage avec une optique coulissante. Distribution Directe/indirecte avec réglage du diamètre de la partie indirecte. Technologie optique Quarkstar. Réglage de la position de l’optique par le dessous du luminaire. Finition blanc (RAL9016). IRC>90, UGR<19, SDCM<3. Flux lumineux : 2500lm, température de couleur de 4000K. Gestion SylSmart Connected. Classe II. Durée de vie : 114.000h (L80B...

CIBSE TM66

Result			
Category	Points Scored	Maximum possible points	Assessment
Product design	62.0	134.0	1.9
Manufacturing	25.2	46.5	2.2
Materials	9.0	24.0	1.5
Ecosystem	20.0	43.0	1.9
Overall performance	116.2	247.5	1.88

How to analyse the score	
0.0 to 0.5	Very poor circular economy performance
0.5 to 1.5	Some circular economy functionality
1.5 to 2.5	Definite/substantial progress to circularity
2.5 to 4.0	Excellent circularity

Technical Memorandum (TM) 66 describes a Circular Economy’s main aims, how it can be achieved and what it’s practice will mean to the different branches of our industry like specifiers, manufacturers, contractors, and Facilities Managers.

The Circular Economy Assement Method for Manufacturing (CEAM-Make)’s list of 66 searching questions, the majority of which askfor back-up evidence, is split into four sections :

- Product Design : Covering topics such as design for long life and repair
- Manufacturing : Additive and subtractive techniques and localisation
- Materials : Usage of recyclable materials rather than virgin
- Ecosystem : Repair or upgrade services to complement circular economy design

The outcome of the assement is a single figure rating by which product comparisons can be made. A TM66 score demonstrates a product’s performance in the context of a Circular Economy

CIBSE (2021) Circular Economy Assessment Method - Make TM66 Digital Tool beta version 22nd October 2021 (London : Chartered Institution of Building Services Engineers)