

Lenzo Large 30W 930 On Board Dim White  
0005537



Features

- The new generation of Lenzo improves the Sylvania track spot range with a simple and slick integral design fixture, with no driver box and no visible screws. Simple and integral design (diameter Ø75mm). Die cast aluminium body, passive cooling heat sink. Adjustable beam angle 18° - 50° Textured White - RAL 9016. Light color temperature: 3000K, warm white, total system power: 30W. Total fixture output: 1925lm, efficacy: 65lm/W, Ra90 typical, LED chromacity: 4 step MacAdam ellipse (SDCM4), IR/UV free light source without heat radiation, ...

CIBSE TM66

Result					
Category	Points Scored	Maximum possible points	Assessment	How to analyse the score	
Product design	41	134.0	1.2	0.0 to 0.5	Very poor circular economy performance
Manufacturing	17.1	46.5	1.5	0.5 to 1.5	Some circular economy functionality
Materials	3	24.0	0.5	1.5 to 2.5	Definite/substantial progress to circularity
Ecosystem	15	43.0	1.4	2.5 to 4.0	Excellent circularity
Overall performance	76.1	247.5	1.15		

Technical Memorandum (TM) 66 describes a Circular Economy’s main aims, how it can be achieved and what it’s practice will mean to the different branches of our industry like specifiers, manufacturers, contractors, and Facilities Managers.

The Circular Economy Assement Method for Manufacturing (CEAM-Make)’s list of 66 searching questions, the majority of which askfor back-up evidence, is split into four sections :

- Product Design :      Covering topics such as design for long life and repair
- Manufacturing :      Additive and subtractive techniques and localisation
- Materials :            Usage of recyclable materials rather than virgin
- Ecosystem :            Repair or upgrade services to complement circular economy design

The outcome of the assement is a single figure rating by which product comparisons can be made. A TM66 score demonstrates a product’s performance in the context of a Circular Economy

CIBSE (2021) Circular Economy Assessment Method - Make TM66 Digital Tool beta version 22nd October 2021 (London : Chartered Institution of Building Services Engineers)