Concord

OPTIX RECESSED 600x600 3L SO 4000K WHT DALI 2023635



Caratteristiche prodotto

• OPTIX RECESSED 600x600 3L SO 4000K WHT DALI is a high efficacy low glare luminaire for office and education applications. Ceiling recessed 600x600 mm. White plastic low glare optics in 3 lines configuration. White RAL9016 fixture body. DALI dimmable. 4000K Neutral White LED, CRI>80, chromaticity tolerance of 3-step MacAdam ellipse. Luminous flux 2900lm. Power consumption 20W. Luminaire efficacy 145lm/W. Lifespan: 48,500 hours L90B10. UGR<19, Luminance at 65°<3000 Cd/m2, IK07, IP20. Photobiological safety risk group 0. Electrical prote...

CIBSE TM66

esult							
Category	Points Scored	Maximum possible points	Assessment]	How to analyse the score		
Product design	76	134.0	2.3		0.0 to 0.5	Very poor circular economy performance	
Manufacturing	23.4	46.5	2		0.5 to 1.5	Some circular economy functionality	
Materials	7	24.0	1.2		1.5 to 2.5	Definite/substantial progress to circularity	
Ecosystem	21	43.0	2		2.5 to 4.0	Excellent circularity	
Overall performance	127.4	247.5	1.88				

Technical Memorandum (TM) 66 describes a Circular Economy's main aims, how it can be achieved and what it's practice will mean to the different branches of our industry like specifiers, manufacturers, contractors, and Facilities Managers.

The Circular Economy Assement Method for Manufacturing (CEAM-Make)'s list of 66 searching questions, the majority of which askfor back-up evidence, is split into four sections :

Product Design :	Covering topics such as design for long life and repair
Manufacturing :	Additive and subtractive techniques and localisation
Materials :	Usage of recyclable materials rather than virgin
Ecosystem :	Repair or upgrade services to complement circular economy design

The outcome of the assement is a single figure rating by which product comparisons can be made. A TM66 score demonstrates a product's performance in the context of a Circular Economy

CIBSE (2021) Circular Economy Assessment Method - Make TM66 Digital Tool beta version 22nd October 2021 (London : Chartered Institution of Building Services Engineers)

