## Concord

## OPTIX LINEAR SURFACE 1200 D/I 3000K ALU DALI 2023809



## Caratteristiche prodotto

• OPTIX LINEAR SURFACE 1200 D/I 3000K ALU DALI is a high efficacy low glare linear luminaire for office and education applications. Suitable for continuous light line installations with accessories separately available. Direct / Indirect lighting with 80% downlight and 20% uplight ratio for ceiling suspended mounting. Size: 1129x90x80mm. Aluminised plastic extra low glare optics in a single line configuration. White RAL9016 fixture body. DALI dimmable. 3000K Warm White LED, CRI>80, chromaticity tolerance of 3-step MacAdam ellipse. Lumi...

## **CIBSE TM66**

Result				
Category	Points Scored	Maximum possible points	Assessment	
Product design	76	134.0	2.3	
Manufacturing	23.4	46.5	2	
Materials	7	24.0	1.2	
Ecosystem	21	43.0	2	
Overall performance	127.4	247.5	1.88	

How to analyse the score		
0.0 to 0.5	Very poor circular economy performance	
0.5 to 1.5	Some circular economy functionality	
1.5 to 2.5	Definite/substantial progress to circularity	
2.5 to 4.0	Excellent circularity	

Technical Memorandum (TM) 66 describes a Circular Economy's main aims, how it can be achieved and what it's practice will mean to the different branches of our industry like specifiers, manufacturers, contractors, and Facilities Managers.

The Circular Economy Assement Method for Manufacturing (CEAM-Make)'s list of 66 searching questions, the majority of which askfor back-up evidence, is split into four sections:

Product Design: Covering topics such as design for long life and repair Manufacturing: Additive and subtractive techniques and localisation Materials: Usage of recyclable materials rather than virgin

Ecosystem : Repair or upgrade services to complement circular economy design

The outcome of the assement is a single figure rating by which product comparisons can be made. A TM66 score demonstrates a product's performance in the context of a Circular Economy

CIBSE (2021) Circular Economy Assessment Method - Make TM66 Digital Tool beta version 22nd October 2021 (London: Chartered Institution of Building Services Engineers)

